


Linear Radiant Ceiling Panel

6" wide panel, 1 tube (1/2" nominal, Type L copper)

zehnder Rittling



A	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'	16'
B	N/A	17"	23"	29"	23.3"	27.3"	31.3"	26.5"	29.5"	26"	28.4"	25.7"	27.7"
C	4	5	5	5	6	6	6	7	7	8	8	9	9

C = Number of cross channels

All tolerances ± 1/16" and angular tolerance ± 1 degree



CONTRACTOR _____
 ARCHITECT _____
 ENGINEER _____
 REPRESENTATIVE _____
 LOCATION _____

ZEHNDER RITTLING
 100 RITTLING BLVD. • BUFFALO, NY USA 14220

JOB:

MODEL: **6" wide panel, 1 tube**



DATE: **July 2014**

DWG.NO.:

Linear Radiant Ceiling Panel

12" wide panel, 2 tubes (1/2" nominal, Type L copper)

zehnder Rittling



A	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'	16'
B	N/A	17"	23"	29"	23.3"	27.3"	31.3"	26.5"	29.5"	26"	28.4"	25.7"	27.7"
C	4	5	5	5	6	6	6	7	7	8	8	9	9

C = Number of cross channels

All tolerances $\pm 1/16"$ and angular tolerance ± 1 degree



CONTRACTOR _____

ARCHITECT _____

ENGINEER _____

REPRESENTATIVE _____

LOCATION _____

ZEHNDER RITTLING
100 RITTLING BLVD. • BUFFALO, NY USA 14220

JOB:

MODEL: **12" wide panel, 2 tubes**


DATE: **July 2014**

DWG.NO.:

Linear Radiant Ceiling Panel

18" wide panel, 3 tubes (1/2" nominal, Type L copper)

zehnder Rittling



A	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'	16'
B	N/A	17"	23"	29"	23.3"	27.3"	31.3"	26.5"	29.5"	26"	28.4"	25.7"	27.7"
C	4	5	5	5	6	6	6	7	7	8	8	9	9

C = Number of cross channels

All tolerances $\pm 1/16"$ and angular tolerance ± 1 degree



CONTRACTOR _____
 ARCHITECT _____
 ENGINEER _____
 REPRESENTATIVE _____
 LOCATION _____

ZEHNDER RITTLING
 100 RITTLING BLVD. • BUFFALO, NY USA 14220

JOB:

MODEL: **18" wide panel, 3 tubes**


DATE: **July 2014**

DWG.NO.:

Linear Radiant Ceiling Panel

24" wide panel, 4 tubes (1/2" nominal, Type L copper)

zehnder Rittling



A	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'	16'
B	N/A	17"	23"	29"	23.3"	27.3"	31.3"	26.5"	29.5"	26"	28.4"	25.7"	27.7"
C	4	5	5	5	6	6	6	7	7	8	8	9	9

C = Number of cross channels

All tolerances $\pm 1/16"$ and angular tolerance ± 1 degree



CONTRACTOR _____
 ARCHITECT _____
 ENGINEER _____
 REPRESENTATIVE _____
 LOCATION _____

ZEHNDER RITTLING
 100 RITTLING BLVD. • BUFFALO, NY USA 14220

JOB:

MODEL: **24" wide panel, 4 tubes**


DATE: **July 2014**

DWG.NO.:

Linear Radiant Ceiling Panel

30" wide panel, 5 tubes (1/2" nominal, Type L copper)

zehnder Rittling



A	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'	16'
B	N/A	17"	23"	29"	23.3"	27.3"	31.3"	26.5"	29.5"	26"	28.4"	25.7"	27.7"
C	4	5	5	5	6	6	6	7	7	8	8	9	9

C = Number of cross channels

All tolerances $\pm 1/16"$ and angular tolerance ± 1 degree



CONTRACTOR _____
 ARCHITECT _____
 ENGINEER _____
 REPRESENTATIVE _____
 LOCATION _____

ZEHNDER RITTLING
 100 RITTLING BLVD. • BUFFALO, NY USA 14220

JOB:

MODEL: **30" wide panel, 5 tubes**


DATE: **July 2014**

DWG.NO.:

Linear Radiant Ceiling Panel

36" wide panel, 6 tubes (1/2" nominal, Type L copper)

zehnder Rittling



A	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'	16'
B	N/A	17"	23"	29"	23.3"	27.3"	31.3"	26.5"	29.5"	26"	28.4"	25.7"	27.7"
C	4	5	5	5	6	6	6	7	7	8	8	9	9

C = Number of cross channels

All tolerances $\pm 1/16"$ and angular tolerance ± 1 degree



CONTRACTOR _____

ARCHITECT _____

ENGINEER _____

REPRESENTATIVE _____

LOCATION _____

ZEHNDER RITTLING
100 RITTLING BLVD. • BUFFALO, NY USA 14220

JOB:

MODEL: **36" wide panel, 6 tubes**

DATE: **July 2014**

DWG.NO.: